

# SYSTÈME DE DÉTECTION D'EAU

**AQUA-STOP®** MODÈLE CP-224 (Panneau de contrôle "Multi Zone Supervision")

## SPÉCIFICATIONS

### Interface série: RS-232

Pour la connection sur un ordinateur local.

### Rapport-ordinateur / logiciel (Serveur-Client)

Logiciel "Multi Zone Supervision " (serveur / client).

Rapport en temps réel de tous les événements.


Description des zones ( éditables).

Graphique interface-utilisateur élaboré .

Fonction de registre des données ("Logs") de toutes les alarmes.

Fonctionne avec Windows® 95, 98, Millennium, NT and X.P.

PC-224



### Alarmes par ordinateur:

Détection d'eau.

Faute de filage.

Bris de communication avec le panneau / Serveur/Client .

Faute de filage , circuits des valves AQUA-STOP® .

### Communication par Internet: ( Application Client)

Protection par passeport.

Connection de clients multiples.

Indicateur d'état de connection avec le serveur.

Rapport en temps réel de détection / filage/ bris de communication.

Message d'alerte affiché pour détection / filage.

Alerte audible (buzzer interne) activée pour détection et/ou faute de filage.

Alerte visuelle / Clignotement de l'icône dans la barre d'état.

Désignation et description des zones. ( éditables)

Fermeture de valves. (par internet)

### Intégrité du système:

Micro processeur protégé par "chien de garde"  
(watchdog).

Circuit externe entier supervisé par le micro processeur.

The screenshot shows a window titled 'AquaStop Server: Zone Definitions'. It contains a form for 'Name of installation' (Riverside Condominiums) and 'Password for remote client connection' (\*\*\*\*\*). Below the form is a table with columns for 'Identification' and 'Action'. The table lists 11 zones across two boards.

	Identification	Action
2	Board 1	Mr. John Things Contact, Fla. (504-123-4444)
3	Board 1	Mrs. Peter St. Onge Montreal, (450-333-5555)
4	Board 1	Meeting rooms, 2nd floor Call C. Smith, (123 4567)
5	Board 1	Boiler rooms Call Joe Plumber ( 555,6666)
6	Board 1	Mr & Mrs. Conners ( Son: Paul 323- 4333)
7	Board 2	Mr. George Pringles Taste the chips and call 333-2222
8	Board 2	Mrs. Temple Call 123-4567
9	Board 2	Mr. Safety Call C. Smith, (123 4567)
10	Board 2	
11	Board 2	

At the bottom of the window, there are two buttons: 'Update current file and exit' (with a green checkmark) and 'Discard changes and exit' (with a red X).

Description des zones (éditables)